



KOPOS KOLÍN a.s.
Havlíčková 432
CZ – 280 94 Kolín IV

EU DECLARATION OF CONFORMITY

No. 1B-EU-11/18-03

In accordance with EU directive 2014/35/EU as amended

We, **KOPOS KOLÍN a. s.**
 Havlíčkova 432
 280 94 Kolín IV
 Czech Republic
 IČ: 61672971
 DIČ: CZ61672971

declare under our sole responsibility that

the product/type: **Terminal block S-66, S-96, SP-96**


manufacturer: **KOPOS KOLÍN a.s. Havlíčkova 432, 280 94 Kolín IV, Czech Republic**

object of the declaration: **Terminal block S-66** - intended into distribution boxes with fixing spacing of 60 mm. Has four separate fields for connecting up to three conductors of up to 4 mm² in diameter. Designed for voltages of up to 400 V.
Terminal block S-96 - intended into distribution boxes with fixing spacing of 86 mm. Has four separate fields for connecting up to four conductors of up to 4 mm² in diameter. Designed for voltages of up to 500 V.
Terminal block SP-96 - intended into distribution boxes with fixing spacing of 86 mm. Has five separate fields for connecting up to four conductors of up to 4 mm² in diameter. Designed for voltages of up to 500 V.

The object of the declaration described above is in conformity with the relevant Union harmonisation legislation, other legislation and regulations:

Regulations Of the European Union	Government Regulations	Standards	Certificates and Test Reports	Other technical specification
2014/35/EU - LVD	Law No. 90/2016 Coll. as amended Government Regulation No. 118/2016 Coll. as amended	ČSN EN 60998-1 ed. 2:05 including amendments (EN 60998-1 :04 including amendments) ČSN EN 60998-2-1 ed.2:05 including amendments (EN 60998-2-1 :04 including amendments)	Test Report No. 600545-01/01 of 30.3.2016 Test Report No. 603154-01/01 of 10.8.2016 Issued by: Elektrotechnický zkušební ústav, Pod Lisem 129, 171 02 Praha 71, Czech Republic	X
Directive RoHS 2011/65/EU as amended	Government Regulation No. 481/2012 Sb.	ZP 344/02 – Methodology for the determination of the elements Pb, Cd, Cr, Hg, Br	Test Report No. 601229-01/01 of 4.4.2016 Issued by: Elektrotechnický zkušební ústav, Pod Lisem 129, 171 02 Praha 71, Czech Republic	X
Regulation 1907/2006 - REACH	X	X	X	Safety data sheets for used materials

By fulfilling the conditions in accordance with these regulations was placed on the product CE marking.



KOPOS KOLÍN a.s.
Havlíčková 432
CZ – 280 94 Kolín IV

Conformity assessment module: **MODUL A: Internal production control**

Technical documentation of products:

- assembly instructions
- Datasheet
- Catalog for products freely available on <http://www.kopos.cz/cs/katalogy>
- Internal documents

KOPOS KOLÍN a.s. company is certificated according to the standard ISO 9001:2015 and ISO 14001:2015 and according to the National program „Safety Enterprise“.

Signed for KOPOS KOLÍN a.s.

Place of issue: Kolín, Czech Republic

Date of issue: 1.3.2018

Ing. Jana Dejmková

Management representative for QMS

KOPOS KOLÍN a.s.
ÚSEK ŘÍZENÍ SYSTÉMU JAKOSTI